



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA193103

Certificate Holder: Guangzhou Sanjing Electric Co., Ltd.
No. 9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong,
P.R. China

Class Description: Non-Prescribed
Product Description: Grid-tied PV Inverter
Trade Name: SAJ
Model No.: R5-12K-T2
Markings: Input: 150-1100Vdc,
MPPT Voltage Range: 160-950Vdc,
Max 12.5A/12.5A, Isc: 15/15A
Output: 3N/PE 380/400V~ 50/60Hz 3x18.2A 13200VA
-40°C to +60°C, IP65, Class I

Standard: IEC 62109-1 Ed 1.0
IEC 62109-2 Ed 1.0
AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: RCM and SAA193103

Date First Registered: 22 November 2019
Date of Expiry: 22 November 2024

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 03-12-19 193103/1a
Correction to Markings

www.jas-anz.org/register