



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA192122

Date of Issue: 26 August 2019

Class Description: Non-Declared

Product Description: Grid-tied PV Inverter

General Modification:

Software version: V1.137

Additional Models	Trade Name	Rating
R5-3K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 12.5A/12.5A, Isc: 15A/15A Output: 230V~ 50Hz 13.1A 3300VA
R5-3.6K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 12.5A/12.5A, Isc: 15A/15A Output: 230V~ 50Hz 16A 3680VA
R5-4K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 12.5A/12.5A, Isc: 15A/15A Output: 230V~ 50Hz 17.4A 4400VA
R5-5K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 12.5A/12.5A, Isc: 15A/15A Output: 230V~ 50Hz 21.8A 4999VA
R5-6K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 12.5A/12.5A, Isc: 15A/15A Output: 230V~ 50Hz 25.1A 6000VA
R5-7K-S2	SAJ	Input: 80-600Vdc, MPPT Voltage Range: 90-550Vdc, Max 25A/12.5A, Isc: 30A/15A Output: 230V~ 50Hz 30.5A 7700VA

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 26-08-19 192122/2