



A P P R O V A L S ®

## Certificate of Suitability

**\*Addendum\***

**Certificate No.:** SAA152214

**Date of Issue:** 4 November 2015

**Class Description:** Non-Declared  
**Product Description:** PV Inverter

<b>Additional Models</b>	<b>Description</b>
Suntrio Plus 4K	Similar to Suntrio Plus 10K except rated: Input: MPPT voltage range 190-900Vdc, Max 1000Vdc, 11/11A Output: 3W/N/PE 480V~ 50Hz, 3x5.8A, 4kW
Suntrio Plus 5K	Similar to Suntrio Plus 10K except rated: Input: MPPT voltage range 240-900Vdc, Max 1000Vdc, 11/11A Output: 3W/N/PE 480V~ 50Hz, 3x7.2A, 5kW
Suntrio Plus 6K	Similar to Suntrio Plus 10K except rated: Input: MPPT voltage range 285-900Vdc, Max 1000Vdc, 11/11A Output: 3W/N/PE 480V~ 50Hz, 3x8.7A, 6kW
Suntrio Plus 8K	Similar to Suntrio Plus 10K except rated: Input: MPPT voltage range 255-900Vdc, Max 1000Vdc, 22/11A Output: 3W/N/PE 480V~ 50Hz, 3x11.6A, 8kW


  
For and on Behalf of  
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:  
[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 04-11-15 152214/2